



**Florida Product Approval No.**  
FL5259 - Latest Revision

| SYSTEM DESCRIPTION                       |               |                  |                 |                       |
|--|---------------|------------------|-----------------|-----------------------|
| DECK THICKNESS                           | BASE SHEET    | UNDERLAYMENT     | FASTENER        | NOTES                 |
| 1 <sup>5</sup> / <sub>32</sub> inch min. | Polyanchor HV | Polystick TU Max | Tin Cap & Nails | Non-HVHZ and HVHZ FBC |

| FASTENER LAYOUT   |           |                        |                     |          |                      |
|-------------------|-----------|------------------------|---------------------|----------|----------------------|
| NO. OF FIELD ROWS | LAP WIDTH | FASTENER SPACING FIELD | PASSING WIND UPLIFT | MDP      | FASTENERS PER SQUARE |
| 3                 | 4 inch    | 8 inch                 | 135 psf             | 67.5 psf | 204                  |

**NOTES:**

- Above pattern is a genetic layout and not project specific.
- Polyglass approved fasteners only to be used.
- Refer to Polyglass website [www.Polyglass.us](http://www.Polyglass.us) for specific product limitations and installation guidelines.
- Refer to any local Building Codes regarding limitations of specific applications.
- Local Codes or requirements of the AHJ supercede Polyglass Requirements and Recommendations.

**POLYGLASS**



**polyglass.us**

1111 West Newport Center Drive  
Deerfield Beach, FL 33442  
Technical Service: (866) 794-9659  
technical@polyglass.com

**Description:**

**POLYANCHOR HV  
FASTENING PATTERN #24  
204 FASTENERS PER SQUARE**

NOT DRAWN TO SCALE

**Number:**

PG-LS-FP-PA-24

**Effective Date:**

112224